



Nuvoco Vistas Corp. Ltd.

NUV/CTR
MAY/QC

C&A PLANT- BHUBANESWAR-III

CONCRETE COMPRESSIVE STRENGTH REPORT

CUSTOMER NAME : EASTBROOK LANDHOLDINGS PVT LTD


DATE OF REPORT : 18.05.24

SITE LOCATION : EASTBROOK LANDHOLDINGS PVT LTD-MEEN

SL. NO.	ID Mark on Cube	Date of Casting DD / MM / YY	Date of Testing DD / MM / YY	Age in Days	Grade of Concrete	Weight Kgs.	Dimensions (CM.)	Load (Kn.)	Compressive Strength (N/mm ²)	Average Comp. Strength (N/mm ²)	Remarks
1	65073	20.04.24	18.05.24	28	M25	8.450	15X15X15	671	29.82	29.90	
2	65073	20.04.24	18.05.24	28	M25	8.400	15X15X15	685	30.44		
3	65073	20.04.24	18.05.24	28	M25	8.300	15X15X15	662	29.42		
1	65073	20.04.24	18.05.24	28	M25	8.550	15X15X15	659	29.29	29.59	
2	65073	20.04.24	18.05.24	28	M25	8.460	15X15X15	670	29.78		
3	65073	20.04.24	18.05.24	28	M25	8.410	15X15X15	668	29.69		



CEMENT
 InstaMix
 FINE
 SPECIAL
 WATER



Follow us on Nuvoco.In /Nuvoco @NuvocoVistas Toll Free: 1800 245 6666 | WhatsApp 98300 17272

Asutosh Sahoo
PREPARED BY :

CHECKED BY :