



Nuvoco Vistas Corp. Ltd.

C&A PLANT- BHUBANESWAR-III

CONCRETE COMPRESSIVE STRENGTH REPORT


NUVOCO
AUG/0

CUSTOMER NAME : EASTBROOK LANDHOLDINGS PVT LTD

DATE OF REPORT : 16.08.24

SITE LOCATION : EASTBROOK LANDHOLDINGS PVT LTD-MEEN

SL. NO.	ID Mark on Cube	Date of Casting DD / MM / YY	Date of Testing DD / MM / YY	Age in Days	Grade of Concrete	Weight Kgs.	Dimensions (CM.)	Load (Kn.)	Compressive Strength (N/mm ²)	Average Comp. Strength (N/mm ²)	Remarks
1	67530	19.07.24	16.08.24	28	M25	8.480	15X15X15	624	27.73	27.45	
2	67530	19.07.24	16.08.24	28	M25	8.360	15X15X15	690	30.67		
3	67530	19.07.24	16.08.24	28	M25	8.450	15X15X15	539	23.96		



Follow us on Nuvoco.in / Nuvoco @NuvocoVistas

Asutosh Sahoo
PREPARED BY :

CHECKED BY :